



- Notes**
1. Gate to be hot dipped galvanised in accordance with BS 5135
 2. Gate to be 3800mm wide and 1100mm high
 3. Gate to be fabricated from 100 x 150 x 5mm RHS
 4. Gate Posts to be 200 x 200 x 5mm SHS
 5. Welding of sections to be in accordance with BS 5135
 6. Concrete Foundation to be ST2, size to be 1000 x 1000 x 1000mm with a minimum post embedment of 750mm
- The swing gate above is based on a nearby gate (pictured opposite) and the contractor will be expected undertake a site visit to get the required fabrication details.



C.Rogers. BSc(Hons), C.Eng., M.I.C.E. DMS, DipM.
Chief Technical Officer.
Environment Directorate
Civic Centre
Ebbw Vale, NP23 6ED

Proposed Gating Order
Access Road to Cwmtillery Lakes
and Welsh Water Pumping Stn.

Drawn: JL	Date: 2005	Chkd:	Date:
Scale(s): NTS		Drg.No. TS2186	